




PLAN VIEW

sample copy - DWG file on paid section

TAG NO	DESCRIPTION	CAPACITY / SIZE	MOC	QTY
T-001	LIFTING STATION	---	RCC	1
P-001 & P-002	RAW SEWAGE TRANSFER PUMPS	---	CI	2
AB-001 & AB-002	AIR BLOWERS	70 m ³ / hr	---	2
BS-001	BAR SCREEN (L x W x H)	300x300x450mm	GRP	1
T-002	MBBR TANK (L x W x H)	2400X1200X2500 mm	GRP	1
T-003	SETTLING TANK (L x W x H)	1200X1200X2500 mm	GRP	1
T-004	CHLORINE CONTACT TANK (500 US GLN)	ø1350 x 1590(H)mm	PE	1
T-005	SLUDGE HOLDING TANK (200 US GLN)	ø1000 x 1155(H)mm	PE	1
P-003 & P-004	FILTER FEED CUM B/W PUMP	0.84 m ³ / hr	SS 304	2
MMF-001	SAND MEDIA FILTER	ø13" x 54"(H)mm	FRP	1
T-006	TREATED WATER TANK (500 US GLN)	ø1330 x 1590(H)mm	PE	1
DT-001	CHLORINE DOSING TANK (50L)	ø400 x 455(H)mm	PE	1
DP-001	CHLORINE DOSING PUMP	2 LPH	---	1
CP-001	CONTROL PANEL (L x W x H)	---	600x200x800mm	1

OEM LOGO		OEM ADDRESS			
Dwg No. XXXXXX		REV.	SHEET	SCALE	SIZE
		00	-	1/000	A1
ISSUED FOR APPROVAL					
REV	DATE	DRAWN BY	TEAM LEAD	JENS. CHECKED	DESCRIPTION
			BL NO	PROJ. ENG.	SIGNATURE
PROJECT DRAWING REVISION					
AREA		SCALE		CAD DRAWING	
PROJECT : SEWAGE TREATMENT PLANT		0 1 2 3 4 5 6 7			
Dwg. TYPE : EQUIPMENT LAYOUT					
DESCRIPTION : 20 CMD STP PLANT					

DESCRIPTION	AREA	S	SERIAL	SL	P	S	REV	DATE	APPROVED BY	DESCRIPTION	BL NO.	PROJ. ENG.	SPECIALS
REFERENCE DRAWINGS										MASTER DRAWING REVISION			
NOTES													

