

TK-01 (CLIENT SCOPE)

RAW WATER TANK

P-01

FEED PUMP
FLOW : 3.8 m3/hr
MATERIAL : SS 304
PRESSURE : 4 bar
POWER : 1.2 kW
MANUFACTURER : GRUNDFOS
MODEL : CM 5-5
QUANTITY : 1No.

MMF-01

MULTI MEDIA FILTER
SIZE : 21"Ø x 62" HEIGHT
FLOW : 3.8 m3/hr
PRESSURE : 4 bar
MOC : FRP
OPERATION : MANUAL
MANUFACTURER : AVENTURA / PENTAIR
QUANTITY : 1 No.

CF-01

CARTRIDGE FILTER
FLOW : 3.8 m3/hr
SIZE : 4.5"Ø x 20"
FILTRATION : 10 MICRON
MANUFACTURER : CCK
QUANTITY : 1 No.

CF-02


CARTRIDGE FILTER
FLOW : 3.8 m3/hr
SIZE : 4.5"Ø x 20"
FILTRATION : 5 MICRON
MANUFACTURER : CCK
QUANTITY : 1 No.

DTK-1

ANTISCALANT DOSING TANK
CAPACITY : 100 Ltr
MOC : POLYETHYLENE
QUANTITY : 1 No.
MANUFACTURER : SEKO

DP-01

ANTISCALANT DOSING PUMP
FLOW : 5 LPH
PRESSURE : 10 Bar
POWER : 0.22 kW
QUANTITY : 1 No.
MANUFACTURER : SEKO
MODEL : AKS 603



LOAD SCHEDULE :					
Sl No.	EQUIPMENT DETAILS	QTY (Nos)	CONFIGURATION	UNIT LOAD (kW)	TOTAL LOAD (kW)
01	FEED PUMP	1	Duty	1.2	1.2
02	HIGH PRESSURE PUMP	1	Duty	4.0	4.0
03	DOSING PUMP	1	Duty	0.22	0.22
04	UV SYSTEM	1	Duty	0.55	0.55
Total Connected Load				5.97 kW (Approx.)	

INSTRUMENT SUPPLY VOLTAGE SCHEDULE :				
Sl No.	INSTRUMENT DETAILS	Qty (Nos)	CONFIGURATION	UNIT VOLTAGE
01	PRESSURE SWITCH	01	Duty	24 VDC
02	LEVEL SWITCH	02	Duty	24 VDC
03	TDS ANALYZER	01	Duty	230 VAC

MULTIMEDIA FILTER VALVE OPEN/CLOSE CONDITION					
MODE	V-3	V-4	V-5	V-6	V-7
SERVICE MODE	OPEN	OPEN	CLOSE	CLOSE	CLOSE
BACKWASH MODE	CLOSE	CLOSE	OPEN	OPEN	CLOSE
RINSE MODE	OPEN	CLOSE	CLOSE	CLOSE	OPEN

S-01

RO PERMEATORS

No. OF PRESS. VESSELS : 4 Nos (4")
No. OF MEMBRANES / VESSELS : 2 Nos
TOTAL No. OF MEMBRANES : 8 Nos
PRESSURE VESSEL MOC : FIBERGLASS REINFORCED PLASTIC
PRESSURE VESSEL MANUFACTURER : CODELINE
MEMBRANE MOC : COMPOSITE POLYAMIDE
MEMBRANE MANUFACTURER : HYDRANAUTICS
MODEL : 4",2E, 300 PSI

TK-02 (CLIENT SCOPE)


PRODUCT WATER TANK

MECHANICAL SYMBOLS


INSTRUMENT SYMBOLS

GENERAL


PIPE LINE/PIPING





GENERAL



EQUIPMENT



VALVES



Instrument Identification and Numbering System											
Property Measured	Instrument Functions										
Description	First Letter J	Trans- mitter T	Indicat- ing I	Status Display B	Record- ing R	Controlling C	Integrating Q	Switching S	Emergency Actuating Z	Alarm A	
Flow	F	FT	FI	HB	FR	FC	FQ	FS	FZ	FA	
Hand	H					HC		HS	HZ	HA	
Level	L	LT	LI			LR	LC		LS	LZ	LA
Pressure	P	PT	PI			PR	PC		PS	PZ	PA
Pressure Differential	PD	PDT	PDI		PDR	PDC		PDS	PDZ	PD	
Quality Analysis or Concentration	Q	QT	QI	QB	QR	QC		QS	QZ	QA	
Speed	S	ST	SI		SR	SC		SS	SZ	SA	
Temperature	T	TT	TI		TR	TC		TS	TZ	TA	
Movement Displacement	G	GT	GI	GB	GR				GZ	GA	
Weight, Mass or Load	W	WT	WI		WR	WC		WS	WZ	WA	
Any Other Property	X	XT	XI		XR	XC			XZ	XA	
Multi Variable	U									UA	
Computing Function	Y							YS	YZ	YA	

ABBREVIATIONS (INSTRUMENTS)

ESD	EMERGENCY SHUTDOWN	TVP	TRUE VAPOUR PRESSURE
H	HIGH	L	LOW
HH	HIGH HIGH	OR	OVERRIDE
FM	FLOW METER	LL	LOW LOW
FE	FLOW ELEMENT	SR	SPLIT RANGE
FI	FLOW INDICATION		
FIT	FLOW INDICATION TRANSMITTER		

CONTINUATION ARROWS :

1) LEFT SIDE OF SHEET:

FROM EQUIPMENT ON PREVIOUS SHEET

TO EQUIPMENT ON PREVIOUS SHEET

2) RIGHT SIDE OF SHEET :


TO EQUIPMENT ON NEXT SHEET

SHEET nr.

FROM EQUIPMENT ON NEXT SHEET


REVISION TRIANGLE

PIPING IDENTIFICATION




ABBREVIATION (GENERAL)

A/G – ABOVE GROUND	RE – REFERENCE ELECTRODE
B/G – BELOW GROUND	RO – RESTRICTION ORIFICE
CC – CORROSION COUPON	RV – RELIEF VALVE
CI – CHEMICAL INJECTION	SC – SAMPLE COLLECTION
CK – CASTELLOC KEYED VALVE	SCR – SCREWED CONNECTION
D – DRAIN	SP – SET POINT
EL – ELEVATION	TSO – TIGHT SHUT OFF
FB – FULL BORE	UC – UTILITY CONNECTION
FO – FLUSHING OUT	V – VENT
GO – GEAR OPERATED	CS – CARBON STEEL
HC – HOSE CONNECTION	PE – POLY ETHYLENE
IH – INSPECTION HOLE	PP – POLY PROPYLENE
LC – LOCKED CLOSED	GRE – GLASS REINFORCED EPOXY
LO – LOCKED OPEN	SS – STAINLESS STEEL
M – MOTOR	DSS – DUPLEX STAINLESS STEEL
MH – MAN HOLE	SDSS – SUPER DUPLEX STAINLESS STEEL
MOV – MOTOR OPERATED VALVE	CS3 – CARBON STEEL WITH 3MM
NC – NORMALLY CLOSED	CORROSION ALLOWANCE
NNF – NORMALLY NO FLOW	CS1D(PE) – CARBON STEEL WITH 1MM
NO – NORMALLY OPEN	CORROSION ALLOWANCE &
PVV – PRESSURE VACUUM VALVE	POLYETHYLENE LINED
CP – CONTROL PANEL	
MMF – MULI MEDIA FILTER	
ERT – ENERGY RECOVERY TURBINE	



PLAN VIEW



VIEW -AA

EQUIPMENT SCHEDULE				
Sr. No.	Equipment Details	Specification / Model No / Size	Make	Quantity (Nos)
1	Feed Water Pump	CM 5-5 / 1.2 kW	Grundfos	1
2	Multimedia Filter	21"(Dia:) x 62" (H)	Aventura /Pentair	1
3	Cartridge Filter	10 Micron, 4.5" x 20"	CCK	1
4	Cartridge Filter	5 Micron, 4.5" x 20"	CCK	1
5	High Pressure Pump	CRN 5-29 / 4 kW	Grundfos	1
6	Pressure Vessel	4" 2 Elements 300 PSI	Pentair	4
7	Dosing Pump	Tekna EVO AKS 603	Seko	1
8	Dosing Tank	100 Ltrs	Seko	1
9	Control Panel	600(L)x500(H)x200(W)mm		1

LEGEND:	
	PROCESS LINE
	REJECT/DRAIN LINE
	BALL VALVE (uPVC)
	CHECK VALVE (uPVC)
	CHECK VALVE (SS)
	GLOBE VALVE (SS)
	BALL VALVE (SS)
	Pi PRESSURE GAUGE
	ROTAMETER


		P.O.Box 30731-Sharjah Sajjah,Emirates Industrial City United Arab Emirates Tel : +971 6 5369880, Fax : +971 6 5369881 www.celarwater.com			
JOB No. CWE/2020/ROP/2934		REV.	SHEET	SCALE	SIZE
		0	1	AS SHOWN	A1
0	03-01-21	VP	ISSUED FOR APPROVAL		
REV	DATE	DRAWN BY	TEAM LEAD	DESCRIPTION	APPROVAL
PROJECT DRAWING REVISION					
AREA : SOMALIA				SCALE : 0 1 2 3 4 5 6	
PROJECT : BRACKISH WATER REVERSE OSMOSIS PLANT				CAD DRAWING	
DRWG. TYPE : EQUIPMENT LAYOUT				AI Nour Group	
DESCRIPTION : 12,000 US GALLONS PER DAY (TDS OF 5000 PPM)				General Trading	


1.ALL DIMENSTIONS ARE IN MM UNLESS OTHERWISE SPECIFIED
1.ALL AIR VENTS SHALL BE CONNECTED TO THE DRAIN HEADER


NOTES



REFERENCE DRAWINGS

MASTER DRAWING REVISION









SAMPLE COPY-DWG FILE ON PAID SECTION