

DESIGN CALCULATIONS (PROCESS)

First Pass

Plant Capacity	m3/D	1000	For 1 streams
	m3/hr.	41.67	
Feed Water TDS	mg/l	48,000.00	
Recovery ratio	%	40.0%	
System High Pressure @ ro feed	bar	72.00	
RO Plant Feed water requirement	m3/hr.	104.2	

A **Design of Borewell pump / Intake pumps**

Raw Water Requirement (max)	m3/hr.	104.2	as RO Projection
Backwash Flow required to fil the BW tank in 8 Hrs	m3/hr.	7.7	7.7
Borewell pump provided (2 numbers provided duty)	m3/hr.	55.9	more than the required flow

Calculation of pump head

Delivery line from Borewell pump to Raw water tank

Pump flow	m3/hr.	111.9	2 duty pumps
Considering velocity	m/s	2	
Required pipe diameter :	mm	141	
Provide pipe of diameter :	mm	150	HDPE - 6"
Actual velocity	m/s	1.8	(BY OTHERS)

Head loss from B-Well pump to raw water tank (Ref. Attached sheet no. 1 for head loss calculations)

Minimum head required	m	21.03	As head loss
Provide Borewell pump of			
Capacity of flow	m/hr	55.93	SP
Head	m	25	Grundfos
Duty + standby	Nos	2+1	

B **Raw Water Tank Capacity:**

Raw Water Requirement	m3/hr.	111.9	
Min Retention Time	Hours	1	
Volume required	m3	111.87	
Provide tank of capacity	m3	150	(By Others)
Actual rentention time	Hours	1.34	

DESIGN CALCULATIONS (PROCESS)

First Pass

C **Design of MMF Feed Pump**

Pre-treatment feed water requirement	m ³ /hr.	104.2	as RO Projection
Backwash flow requirement (to fill the tank)	m ³ /hr.	7.7	
Total Feed flow required	m ³ /hr.	111.9	

Calculation of pump head

Suction line from raw water tank to MMF feed pump

Pump flow	m ³ /hr.	111.9	
Considering velocity	m/s	1.5	
Required pipe diameter :	mm	162	
Provide pipe of diameter :	mm	150	uPVC -6"
Actual velocity	m/s	1.76	

Head loss from raw water tank to suction of feed pump (Ref. Attached sheet no.2 for head loss calculations)

Minimum head required	m	2.13	a
-----------------------	---	------	----------

Delivery line from MMF feed pump to MMF

Pump flow	m ³ /hr.	111.9	
Considering velocity	m/s	2.5	
Required pipe diameter :	mm	126	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.8	

Head loss from raw water feed pump to MMF (Ref. Attached sheet no. 3 for head loss calculations)

Minimum head required	m	3.43	b
-----------------------	---	------	----------

Head loss calculations in MMF

Maximum allowable head loss 15 bar

Consider head loss in filter 15 m during service flow	m	15	c
---	---	----	----------

DESIGN CALCULATIONS (PROCESS)

First Pass

Delivery line from MMF outlet to Cartridge Filter inlet

Pump flow	m ³ /hr.	104.2	
Considering velocity	m/s	2.5	
Required pipe diameter :	mm	121	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.64	
Head loss from MMF to filtered water tank (Ref. Attached sheet no. 4 for head loss calculations)			
Minimum head required	m	2.36	d

Head loss calculations in Cartridge Filter

Maximum allowable head loss .8 bar

Consider head loss in filter 8 m during service flow	m	8	e
--	---	---	----------

Delivery line from Cartridge filter to HPP Suction

Pump flow	m ³ /hr.	104.2	
Considering velocity	m/s	2	
Required pipe diameter :	mm	136	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.64	
Head loss from cartridge filter to HPP suction (Ref. Attached sheet no. 8 for head loss calculations)			
Minimum head required	m	2.34	f

Provide 2 no. of MMF feed pump (Duty + Store Spare)

Feed pump	m/hr	111.9	NB
Head (a+b+c+d+e+f+10)	m	43	Grundfoss

D Selection of Multi Media Filter (MMF)

RO feed flow	M ³ /hr	104.17	
Actual feed flow including B.W flow	m ³ /hr	111.87	
Design Velocity	m/hr	11.00	10- 11M/Hr
Surface Area required	m ²	10.17	
No of duty media	No	5.00	1 standby filter
Diameter of media filter required	Meter	1.61	
	Inch	63.35	

Media selected	Inch	63.00	63 x 72 MMF
Actual Velocity of filtration	Meter/hour	10.36	1.6002

E Selection of Backwash Tank

Backwash Water Requirement	m ³ /hr.	49.5	Each filter for total MMF
	m ³ /min	4.1	
Min Retention Time	Minutes	15	
Volume required	m ³	61.9	
Provided tank of capacity	m ³	100	as per client specs

DESIGN CALCULATIONS (PROCESS)

First Pass

Actual retention time	Minutes	24	By Others
-----------------------	---------	----	-----------

F Design of Media Filter Backwash pump

Backwash Velocity	m/hr	25
Media filter surface area	m ²	1.98
Backwash flow Rate	m ³ /hr	49.49
Backwash duration	Min	15.00
R.O. Plant feed water requirement	cu.m/hr.	104.17
Backwash duration (@ minimum)	hrs	8.00
Backwash flow / day	cu.m./day	185.60
Backwash flow / hr	cu.m./hr	7.73

Calculation of pump head

Suction line Backwash Pump

Pump flow	cu.m/hr.	49.49	
Considering velocity in suction line	m/s	1.5	
Required pipe diameter :	mm	108	
Provide pipe of diameter : 5" minimum	mm	100	uPVC - 4"
Actual velocity	m/s	1.75	
Head loss in the suction line backwash pump (Ref. Attached sheet no. 5 for head loss calculations)			
Minimum head required	m	2.14	a

Delivery line backwash pump

Pump flow	cu.m/hr.	49.49	
Considering velocity in discharge line	m/s	2	
Required pipe diameter	mm	94	
Provide pipe of diameter :	mm	100	uPVC - 4"
Actual velocity	m/s	1.75	
Head loss for discharge pipe from Backwash pump to media filter inlet (Ref. Attached sheet no. 6 for head loss calculations)			
Minimum head required	m	5.58	b

Head loss for discharge pipe from media filter to drain (Ref.

Attached sheet no. 7 for head loss calculations)

Minimum head required	m	2.91	c
-----------------------	---	------	----------

Head loss calculations in Media filters

Maximum allowable head loss- 1 bar

Hence consider head loss in filter as 10m	m	10	d
---	---	----	----------

Backwash Pump Head	m	20.64
--------------------	---	-------

(a+b+c+d)

Provide 1 no. Backwash water pump of

Capacity	m ³ /hr	49.49	Grundofss
----------	--------------------	--------------	-----------

DESIGN CALCULATIONS (PROCESS)**First Pass**

	Head	m	21	NB
G	Air Scouring Blower Calculation			
	Feed flow during normal service	m ³ /hr	111.87	
	Design Filtration velocity	m ³ /m ² /hr	11.00	
	Air scour velocity	m ³ /m ² /hr	26.00	
	Filtration area each filter	M ²	1.98	
	Air scour rate required @ 0.5 bar	m ³ /hr	51.47	
H	Selection of Cartridge Filter			
		<i>micron</i>	5	
	Feed Flow	m ³ /hr	104.17	
	Flow each 2.5"x40" - 5 Micron cartridge filter	M ³ /hr	4.90	
	No of Cartridge filters	Nos	26.04	
	CF housing each CF	Nos	9.00	
	No of CF housing	Nos	2.89	
	CF selected	Nos	3.00	1 standby
I	Selection of Pressure Exchanger (ERI)			
	PX model		PX-140S	(Ref. ERI design)
	Number of units		3	
	PX unit flow	m ³ /hr	20.8	
	Low pressure Inlet	bar	1.6	
	High Pressure Outlet	bar	70.0	
	High pressure Inlet	bar	70.5	
	Low Pressure Outlet	bar	1.0	
	PX efficiency	%	95.0%	
	Operating capacity	%	65.5%	
J	Selection of PX Booster Pump			
	ERI PX booster model	50 Hz	HP-1253	(Ref. ERI design projection)
	Number of units		2	
	PX booster efficiency	%	64%	
	Motor Efficiency	%	91%	
	Total PX booster flow rate	m ³ /hr	60.2	
	Inlet Pressure	bar	70.0	
	Outlet Pressure	bar	72.0	
	Differential pressure	bar	2.0	
	Total booster power	kW	5.8	
K	Selection of High Presssure Pump			
	Max. inlet pressure required at the RO Plant module	bar	72.00	(Ref. RO Membrane design projection)
	Select 1 number of HPP (1 duty)			
	capcaity	m3	44	Membrane Projectn
	pressure	bar	72	-

DESIGN CALCULATIONS (PROCESS)

First Pass

L	Design of Reverse Osmosis Module	no	7ele x 6nos	(Ref. Membrane
	Membrane - Hydranautics- SWC5 MAX	no	84	design projections)
	Pressure Vessel	no	12	For each 500 m3
	membrane per vessel	no	7	

Design of HPP Discharge Pipeline

Pump flow	m3/hr	43.9	
Considering velocity in pipeline	m/s	3	
Required pipe diameter :	mm	72	
Provide pipe of diameter :	mm	80	DSS - 3"
Actual velocity	m/s	2.43	

Design of Reject Pipeline

System flow	m3/hr	62.50	Membrane Projectn
Considering velocity in pipeline	m/s	2.5	
Required pipe diameter :	mm	94	
Provide pipe of diameter :	mm	100	DSS - 4"
Actual velocity	m/s	2.21	

Design of PX booster Pump suction pipeline

Pump flow	m3/hr	62.50	Membrane Projectn
Considering velocity in pipeline	m/s	2.5	
Required pipe diameter :	mm	94	
Provide pipe of diameter :	mm	100	DSS - 4"
Actual velocity	m/s	2.21	

Design of PX booster Pump Discharge pipeline

Pump flow	m3/hr	62.50	
Considering velocity in pipeline	m/s	2.5	
Required pipe diameter :	mm	94	
Provide pipe of diameter :	mm	100	DSS - 4"
Actual velocity	m/s	2.21	

Design of High Pump suction pipeline

Pump flow	m3/hr	43.94	
Considering velocity in pipeline	m/s	2	
Required pipe diameter :	mm	88	
Provide pipe of diameter :	mm	100	UPVC - 4"
Actual velocity	m/s	1.55	

Design of permeate pipeline

System flow	m3/hr	41.67	
Considering velocity in pipeline	m/s	1.5	
Required pipe diameter :	mm	99	
Provide pipe of diameter :	mm	100	uPVC - 4"

DESIGN CALCULATIONS (PROCESS)

First Pass

Actual velocity	m/s	1.47
-----------------	-----	------

M Design of Flushing Tank

Flushing volume required = volume of pressure tube with soaked membranes + residual solution in cleaning tank + vol. In interconnecting piping

Volume / soaked membrane	Ltrs	68
	m3	0.068
VoL.of pressure tube with soaked memb	m3	5.9976
Pipe line size (Dia)	mm	100
Pipe line size (Radius)	m	0.05
Overall length of all interconnecting pipes	m	58
Volume of interconnecting pipe	m3	0.3925
	m3	6.39
Flush tank volume required	Gallons	1686.9864
	m3	10.00
Flushing tank volume Designed / Provided	Gallons	2642

N Design of flush pump

Total volume to be flushed out 100% in 5mins	gallons	2642
Flow	gpm	528
	m3/hr	120.01
Flush flow rate selected	m3/hr	120

Calculation of pump head:

Suction line from flush tank to flush pump suction

Pump flow	cu.m/hr.	120
Considering velocity 2 m/s. in pump discharge line	m/s	2
Required pipe diameter :	mm	146
Provide pipe of diameter :	mm	150
Actual velocity	m/s	1.89
		uPVC - 6"

Head loss flush tank to flush pump suction (Ref.Attached sheet no.9 for head loss calculations)

Minimum head required	m	1.73	a
-----------------------	---	------	----------

Delivery line from flush pump to RO suction (outlet of CF)

Pump flow (max)	cu.m/hr.	120
Considering velocity in pump discharge line	m/s	2.5
Required pipe diameter .	mm	130
Provide pipe of diameter :	mm	150
Actual velocity	m/s	1.89
		uPVC - 6"

Head loss flush pump delivery to pressure vessels (Ref.Attached sheet no.10 for head loss calculations)

Minimum head required	m	4.35	b
-----------------------	---	------	----------

DESIGN CALCULATIONS (PROCESS)

First Pass

Head loss calculations in Pressure vessels

Maximum allowable head loss 1 bar

Consider head loss in Pressure vessels 10 m	m	10	c
---	---	----	---

Head loss Delivery from RO to Brine pit

Pump flow (max)	cu.m/hr.	120	
-----------------	----------	-----	--

Considering velocity in pump discharge line	m/s	2	
---	-----	---	--

Required pipe diameter .	mm	146	
--------------------------	----	-----	--

Provide pipe of diameter :	mm	150	
----------------------------	----	-----	--

Actual velocity	m/s	1.89	
-----------------	-----	------	--

Head loss from RO to Brine pit (Ref.Attached sheet no.11 for head loss calculations)

Minimum head required	m	2.49	d
-----------------------	---	------	---

Provide 1 no. flush pump of

Capacity	m3/hr	120.00	Grundfos
Head Required minimum	m	19	

O Design of CIP Tank

Flushing volume required = volume of pressure tube with soaked membranes + residual solution in cleaning tank + vol. In interconnecting piping

Volume / soaked membrane	Ltrs	68	
	m3	0.068	

VoL.of pressure tube with soaked memb	m3	5.9976	DOW MANUAL
--	-----------	---------------	------------

Pipe line size (Dia)	mm	150	
----------------------	----	-----	--

Pipe line size (Radius)	m	0.075	
-------------------------	---	-------	--

Overall length of all interconnecting pipes	m	50	
---	---	----	--

Volume of interconnecting pipe	m3	0.883125	
---------------------------------------	-----------	-----------------	--

	m3	6.88	
--	----	------	--

CIP tank volume required	Gallons	1816.5114	
--------------------------	---------	-----------	--

	m3	10.00	
--	----	-------	--

CIP tank volume Designed / Provided	Gallons	2642	
-------------------------------------	---------	------	--

P Design of CIP pump

Total volume to be recycled 100% in 5mins	gallons	2642	
---	---------	------	--

Flow	gpm	528	
------	-----	-----	--

	m3/hr	120.01	
--	-------	--------	--

Cleaning flow rate selected	m3/hr	45	
-----------------------------	-------	----	--

Calculation of pump head:

Suction line from CIP tank to CIP pump suction

Pump flow	cu.m/hr.	120	
-----------	----------	-----	--

Considering velocity 1 m/s. in pump discharge line	m/s	2	
--	-----	---	--

Required pipe diameter :	mm	146	
--------------------------	----	-----	--

DESIGN CALCULATIONS (PROCESS)

First Pass

Provide pipe of diameter :	mm	100	uPVC - 4"
Actual velocity	m/s	4.24	

Head loss CIP tank to CIP pump suction (Ref.Attached sheet no.12 for head loss calculations)

Minimum head required	m	2.64	a
-----------------------	---	------	----------

Delivery line from CIP pump to CIP Filter

Pump flow (max)	cu.m/hr.	120	
Considering velocity in pump discharge line	m/s	2	
Required pipe diameter .	mm	146	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.89	
Head loss CIP pump delivery to CIP Filter (Ref.Attached sheet no.13 for head loss calculations)			
Minimum head required	m	2.68	b

Head loss calculations in cleaning cartridge filter

Maximum allowable head loss 0.75 bar

Hence considered head loss in filter as	m	7.5	c
---	---	-----	----------

Delivery line from cleaning cartridge filter to RO System

Pump flow	cu.m/hr	120	
Considering velocity in pump discharge line	m/s	2.5	
Required pipe diameter	mm	130	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.89	
Head loss from cleaning cartridge filter to R.O. System (Ref.Attached sheet no.14 for head loss calculations)			
Minimum head required	m	2.68	d

Head loss calculations in R.O. System for cleaning operation

Maximum allowable head loss across membranes 1 bar	m	10	e
--	---	----	----------

Recirculation line from R.O. System in cleaning tank

Pump flow	cu.m/.hr	120	
Considering velocity pump discharge line	m/s	2.5	
Required pipe diameter :	mm	130	
Provide pipe of diameter :	mm	150	uPVC - 6"
Actual velocity	m/s	1.89	

Head loss from recirculation line from RO System to cleaning tank

(Ref. Attached sheet no.15 for head loss calculation)

Minimum head required	m	1.75	f
-----------------------	---	------	----------

Hence total pumping head required for cleaning pump:

DESIGN CALCULATIONS (PROCESS)

First Pass

Total head loss from cleaning tank to suction of cleaning pump +
pressure loss from cleaning pump to Cleaning cartridge filter +
pressure loss across cleaning cartridge filter + head loss from
cleaning cartridge filter to R.O. System + head loss across m

a+b+c+d+e+f m 28.0

Provide 1 no. cleaning pump of

Capacity	m3/hr	120	Grundfos
Minimum head required	m	28	Grundfos

Q Selection of Cleaning Cartridge Filter

Feed Flow m3/hr 120

Max. flow handled by Dia 2.5" x 40"X long 9 nos cartridge of 5 micron nominal rating m3/hr 30

Hence no. of cartridge required 4.00

No. of 2.5" x 40" x 7 Cartridge provided 4 considered UPVC

Max Feed flow that can be handled 120 make filters

SECOND PASS

R	Plant Capacity	m3/D	1000	1 x 100 m3 stream
	Plant Capacity	m3/hr.	41.67	20.86 / stream
	Blending from first pass	m3/hr.	0.00	
	Permeate from Second pass	m3/hr.	41.67	
	Brine recirculation from pass 2	m3/hr.	0	
	Feed Water TDS	mg/l	500.00	
	Recovery ratio	%	90.0%	
	System High Pressure @ ro feed	bar	10.00	
S	RO Plant Feed water requirement	m3/hr.	46.30	
	Total feed flow		46.30	(Ref. RO Membrane design projection)

Intermedeate Water Tank Capacity:

Feed Water Flow	m3/Hr	46.30	
Min Retention Time	Min	5	
Volume required	Gal	1019	(Ref. Membrane design projections)
Provide tank of capacity	Gal	1000	
Actual rentention time	Min	4.9	

Selection of High Presssure Pump

Max. inlet pressure required at the RO Plant module bar 10

Select one number of HPP

capcaity	m3	46.30
pressure	bar	18

DESIGN CALCULATIONS (PROCESS)

First Pass

Design of Reverse Osmosis Module

	no	7ele x 6nos
Membrane - Hydranautics - SWC5 MAX	no	42
Pressure Vessel	no	6
membrane per vessel	no	7
Pressure Rating Minimum	psi	600

SAMPLE COPY- EXCEL FILE ON PAID SECTION

Sheet No. 1
Head Loss Calculation

Head loss calculation for	=	Borewell pump to Raw Water Tank
Flow (cum/hr)	=	111.9 m ³ /hr
Diameter (mm)	=	150 mm
Hence, velocity (m/sec)	=	1.76 m/sec
Constant C	=	130
Straight length (m)	=	200 m
Static head (m)	=	15 m
Velocity Head ($v^2/2g$)	=	0.16 m

Head Loss In Fittings

Fitting	Quantity	Reynolds Factor	Head Loss ($kv^2/2g$)
Elbows, 90 deg	5	0.29	0.229
Elbows, 45 deg	3	0.14	0.066
Sudden contraction	2	0.88	0.277
Sudden engl.	2	1.76	0.554
Tee-90 deg	1	0.35	0.055
Valves	3	0.25	0.118
NRV	1	0.2	0.315
Strainer (approximate)	0	0.75	0.000
Exit	1	0.75	0.118
Total			1.733

Friction Loss in Pipes

According to the Empirical formulae for the calculation of friction loss:

$$\text{Friction head loss} = 6.78 (v/C)^{1.852} (D)^{-1.165} = 0.0213813 \text{ m/m}$$

$$\text{Therefore friction loss in pipe} = 200 = 4.28 \text{ m}$$

$$\text{Total Head Loss (m)} = (\text{Loss in Fittings} +) = 6.03 \text{ m}$$

$$\text{Minimum Head Required} = (\text{Total Head Loss} +) = 21.03 \text{ m}$$

Sheet No. 2
Head Loss Calculation

1	Head loss calculation for	:	Raw water tank to Suction of MMF feed pump
2			
3	Flow (cum/hr)	=	111.87 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.76 m/sec
6	Constant C	=	120
7	Straight length (m)	=	5 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.16 m

Head Loss In Fittings

13	Fitting	Quantity	Reynolds Factor	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	3	0.29	0.137
16	Elbows, 45 deg	2	0.14	0.044
17	Sudden contraction	1	0.88	0.139
18	Sudden engl.	1	1.76	0.277
19	Tee-90 deg	2	0.35	0.110
20	Valves	4	0.25	0.158
21	NRV	0	2	0.000
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.118
24	Total			0.983

Friction Loss in Pipes

According to the Empirical formulae for the calculation of friction loss:

Friction head loss = $6.78 (V/C)^{1.852} (D)^{-1.165}$ = **0.025 m/m**

Therefore friction loss in pipe = **0.12 m**

Total Head Loss (m) (Loss in Fittings +) = **1.13 m**

Minimum Head Required (Total Head Loss +) = **2.13 m**

Sheet No. 3
Head Loss Calculation

1	Head loss calculation for	:	Raw Water feed pump to MMF
2			
3	Flow (cum/hr)	=	111.87 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.76 m/sec
6	Constant C	=	120
7	Straight length (m)	=	3 m
8	Static head (m)	=	2 m
9	Velocity Head ($v^2/2g$)	=	0.16 m

Head Loss In Fittings

13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	5	0.29	0.229
16	Elbows, 45 deg	3	0.14	0.066
17	Sudden contraction	1	0.88	0.139
18	Sudden engl.	1	1.76	0.277
19	Tee-90 deg	2	0.35	0.110
20	Valves	2	0.25	0.079
21	NRV	1	0.75	0.315
22	Strainer (approximate)	0	0.75	0.000
23	Exit	1	0.75	0.118
24	Total			1.333

Friction Loss in Pipes

27	According to the Empirical formulae for the calculation of friction loss:			
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	=	0.025 m/m
29				
30	Therefore friction loss in pipe	3	=	0.07 m
31				
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	=	1.43 m
33				
34	Minimum Head Required	(Total Head Loss + Static Head)	=	3.43 m

Sheet No. 4
Head Loss Calculation

1	Head loss calculation for	:	MMF outlet to Cartridge Filter inlet
2			
3	Flow (cum/hr)	=	104.17 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.64 m/sec
6	Constant C	=	120
7	Straight length (m)	=	5 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.14 m

Head Loss In Fittings

13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	5	0.29	0.198
16	Elbows, 45 deg	3	0.14	0.057
17	Sudden contraction	1	0.82	0.112
18	Sudden engl.	1	1.64	0.224
19	Tee-90 deg	2	0.35	0.096
20	Valves	2	0.25	0.068
21	NRV	1	0.25	0.273
22	Strainer (approximate)	0	0.75	0.000
23	Exit	2	0.75	0.205
24	Total			1.233

Friction Loss in Pipes

27	According to the Empirical formulae for the calculation of friction loss:			
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	=	0.022 m/m
29				
30	Therefore friction loss in pipe	5	=	0.11 m
31				
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	=	1.36 m
33				
34	Minimum Head Required	(Total Head Loss + Static Head)	=	2.36 m

Sheet No. 5
Head Loss Calculation

1	Head loss calculation for	:	Filtrate tank outlet to suction of Backwash pump
2			
3	Flow (cum/hr)	=	49.49 m ³ /hr
4	Diameter (mm)	=	100 mm
5	Hence, velocity (m/sec)	=	1.75 m/sec
6	Constant C	=	120
7	Straight length (m)	=	5 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.16 m
10			
11	Head Loss In Fittings		
12			
13	Fitting	Quantity	Reynolds Factor (k)
14			Head Loss ($kv^2/2g$)
15	Elbows, 90 deg	4	0.29
16	Elbows, 45 deg	3	0.14
17	Sudden contraction	1	0.88
18	Sudden enl.	1	1.75
19	Tee-90 deg	1	0.35
20	Valves	2	0.25
21	NRV	0	2
22	Strainer (approximate)	0	75
23	Exit	1	0.75
24	Total		0.907
25			
26	Friction Loss in Pipes		
27	According to the Empirical formulae for the calculation of friction loss:		
28	Friction head loss	$= 6.78 (v/100)^{1.852} (D)^{-1.165}$	0.039 m/m
29			
30	Therefore friction loss in pipe	5	0.20 m
31			
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	1.14 m
33			
34	Minimum Head Required	(Total Head Loss + Static Head)	2.14 m

Sheet No. 6
Head Loss Calculation

1 **Head loss calculation for** : **Backwash Pump to MMF**

2			
3	Flow (cum/hr)	=	49.49 m ³ /hr
4	Diameter (mm)	=	100 mm
5	Hence, velocity (m/sec)	=	1.75 m/sec
6	Constant C	=	120
7	Straight length (m)	=	20 m
8	Static head (m)	=	3 m
9	Velocity Head ($v^2/2g$)	=	0.16 m
10			

11 **Head Loss In Fittings**

12				
13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	5	0.29	0.226
16	Elbows, 45 deg	4	0.14	0.087
17	Sudden contraction	2	0.88	0.273
18	Sudden engl.	2	1.75	0.547
19	Tee-90 deg	2	0.35	0.109
20	Valves	2	0.25	0.078
21	NRV	1	2	0.312
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.117
24	Total			1.751

25

26 **Friction Loss in Pipes**

27	According to the Empirical formulae for the calculation of friction loss:			
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	=	0.039 m/m
29				
30	Therefore friction loss in pipe	20	=	0.79 m
31				
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	=	2.58 m
33				
34	Minimum Head Required	(Total Head Loss + Static Head)	=	5.58 m

Sheet No.7
Head Loss Calculation

1	Head loss calculation for	:	Back wash drain from MMF unit to brine pit
2			
3	Flow (cum/hr)	=	49.49 m ³ /hr
4	Diameter (mm)	=	100 mm
5	Hence, velocity (m/sec)	=	1.75 m/sec
6	Constant C	=	120
7	Straight length (m)	=	25 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.16 m
10			

Head Loss In Fittings

Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14			
15 Elbows, 90 deg	6	0.29	0.272
16 Elbows, 45 deg	0	0.14	0.000
17 Sudden contraction	0	0.88	0.000
18 Sudden engl.	1	1.75	0.273
19 Tee-90 deg	2	0.35	0.109
20 Valves	3	0.25	0.117
21 NRV	0	2	0.000
22 Strainer (approximate)	0	75	0.000
23 Exit	1	0.75	0.117
24 Total			0.889

Friction Loss in Pipes

27	According to the Empirical formulae for the calculation of friction loss:		
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	= 0.039 m/m
29			
30	Therefore friction loss in pipe	25	= 0.99 m
31			
32	Total Head Loss (m)	Loss in Fittings + Friction Loss in pipe)	= 1.91 m
33			
34	Minimum Head Required	(Total Head Loss + Static Head)	= 2.91 m

Sheet No. 8
Head loss Calculation

1 **Head loss calculation for** : **Cartridge filter outlet to High Pressure pump suction**

2			
3	Flow (cum/hr)	=	104.17 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.64 m/sec
6	Constant C	=	120
7	Straight length (m)	=	10 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.14 m

10

11 **Head Loss In Fittings**

12	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
13				
14				
15	Elbows, 90 deg	8	0.29	0.317
16	Elbows, 45 deg	2	0.14	0.038
17	Sudden contraction	1	0.82	0.112
18	Sudden engl.	1	1.64	0.224
19	Tee-90 deg	0	0.35	0.000
20	Valves	1	0.25	0.034
21	NRV	1	2	0.273
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.102
24	Total			1.101

25

26 **Friction Loss in Pipes**

27	According to the Empirical formulae for the calculation of friction loss:			
28	Friction head loss	$= 6.78 (v/1000)^{4.852} (D)^{-1.165}$	=	0.022 m/m
29				
30	Therefore friction loss in pipe	10	=	0.22 m
31				
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	=	1.34 m
33				
34	Minimum Head Required	(Total Head Loss + Static Head)	=	2.34 m

Sheet No. 9
Head Loss Calculation

1 **Head loss calculation for** : **Flush tank outlet to Suction of flushpump**

2			
3	Flow (cum/hr)	=	120 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.89 m/sec
6	Constant C	=	120
7	Straight length (m)	=	3 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.18 m
10			

11 **Head Loss In Fittings**

12				
13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	5	0.29	0.263
16	Elbows, 45 deg	0	0.14	0.000
17	Sudden contraction	1	0.94	0.171
18	Sudden engl.	0	1.89	0.000
19	Tee-90 deg	0	0.35	0.000
20	Valves	1	0.25	0.045
21	NRV	0	2	0.000
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.136
24	Total			0.615

26 **Friction Loss in Pipes**

27 According to the Empirical formulae for the calculation of friction loss:

28 Friction head loss = $6.78 (v/100)^{8.52} (D)^{-1.165}$ = **0.028 m/m**

30 Therefore friction loss in pipe = **0.08 m**

32 Total Head Loss (m) (Loss in Fittings + Friction Loss in pipe) = **0.73 m**

34 Minimum Head Required (Total Head Loss + Static Head) = **1.73 m**

Sheet No. 10
Head Loss Calculation

1	Head loss calculation for	:	Flush pump to RO suction
2			
3	Flow (cum/hr)	=	120 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.89 m/sec
6	Constant C	=	120
7	Straight length (m)	=	3 m
8	Static head (m)	=	2 m
9	Velocity Head ($v^2/2g$)	=	0.18 m
10			
11	Head Loss In Fittings		
12			
13	Fitting	Quantity	Reynolds Factor (k)
14			Head Loss ($kv^2/2g$)
15	Elbows, 90 deg	7	0.29
16	Elbows, 45 deg	2	0.14
17	Sudden contraction	1	0.94
18	Sudden engl.	1	1.89
19	Tee-90 deg	2	0.35
20	Valves	4	0.25
21	NRV	2	0.75
22	Strainer (approximate)	0	0.75
23	Exit	2	0.75
24	Total		2.238
25			
26	Friction Loss in Pipes		
27	According to the Empirical formulae for the calculation of friction loss:		
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	0.028 m/m
29			
30	Therefore friction loss in pipe	3	0.08 m
31			
32	Total Head Loss (m)	(Loss in Fittings + Friction Loss in pipe)	2.35 m
33			
34	Minimum Head Required	(Total Head Loss + Static Head)	4.35 m

Sheet No. 11
Head Loss Calculation

1 **Head loss calculation for** : **RO To Brine pit**

2		
3	Flow (cum/hr)	= 120 m3/hr
4	Diameter (mm)	= 150 mm
5	Hence, velocity (m/sec)	= 1.89 m/sec
6	Constant C	= 120
7	Straight length (m)	= 25 m
8	Static head (m)	= 1 m
9	Velocity Head ($v^2/2g$)	= 0.18 m

11 **Head Loss In Fittings**

12			
13	Fitting	Quantity	Reynolds Factor (k)
14			Head Loss ($kv^2/2g$)
15	Elbows, 90 deg	4	0.29
16	Elbows, 45 deg	0	0.14
17	Sudden contraction	0	0.94
18	Sudden engl.	0	1.89
19	Tee-90 deg	0	0.35
20	Valves	1	0.25
21	NRV	1	0.75
22	Strainer (approximate)	0	0.75
23	Exit	1	0.75
24	Total		0.754

26 **Friction Loss in Pipes**

27 According to the Empirical formulae for the calculation of friction loss:

28 Friction head loss = $6.78 (v/C)^{1.852} (D)^{-1.165}$ = **0.028 m/m**

30 Therefore friction loss in pipe = **0.71 m**

32 Total Head Loss (m) = (Loss in Fittings + Friction Loss in pipe) = **1.49 m**

34 Minimum Head Required = (Total Head Loss + Static Head) = **2.49 m**

Sheet No. 12
Head Loss Calculation

1 **Head loss calculation for** : **CIP tank outlet to Suction of CIP pump**

2			
3	Flow (cum/hr)	=	120 m ³ /hr
4	Diameter (mm)	=	100 mm
5	Hence, velocity (m/sec)	=	4.24 m/sec
6	Constant C	=	120
7	Straight length (m)	=	3 m
8	Static head (m)	=	1 m
9	Velocity Head ($v^2/2g$)	=	0.92 m
10			

11 **Head Loss In Fittings**

12				
13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	5	0.29	0.263
16	Elbows, 45 deg	0	0.14	0.000
17	Sudden contraction	1	2.12	0.385
18	Sudden engl.	0	4.24	0.000
19	Tee-90 deg	0	0.35	0.000
20	Valves	1	0.25	0.045
21	NRV	0	2	0.000
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.136
24	Total			0.829

26 **Friction Loss in Pipes**

27 According to the Empirical formulae for the calculation of friction loss:

28 Friction head loss = $6.78 (v/100)^{8.52} (D)^{-1.165}$ = **0.203 m/m**

30 Therefore friction loss in pipe 3 = **0.61 m**

32 Total Head Loss (m) (Loss in Fittings + Friction Loss in pipe) = **1.64 m**

34 Minimum Head Required (Total Head Loss + Static Head) = **2.64 m**

Sheet No. 13
Head Loss Calculation- 1

1	Head loss calculation for	:	CIP Pump to Cleaning Cartridge Filtler
2			
3	Flow (cum/hr)	=	120 m3/hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.89 m/sec
6	Constant C	=	120
7	Straight length (m)	=	5 m
8	Static head (m)	=	1.5 m
9	Velocity Head ($v^2/2g$)	=	0.18 m
10			

Head Loss In Fittings

Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14			
15 Elbows, 90 deg	4	0.29	0.210
16 Elbows, 45 deg	0	0.14	0.000
17 Sudden contraction	0	0.94	0.000
18 Sudden engl.	1	1.89	0.342
19 Tee-90 deg	0	0.35	0.000
20 Valves	2	0.25	0.091
21 NRV	1	0.75	0.363
22 Strainer (approximate)	0	0.75	0.000
23 Exit	0	0.75	0.000
24 Total			1.006

Friction Loss in Pipes

27	According to the Empirical formulae for the calculation of friction loss:		
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	= 0.028 m/m
29			
30	Therefore friction loss in pipe	5	= 0.14 m
31			
32	Total Head Loss (m)	Loss in Fittings + Friction Loss in pipe)	= 1.18 m
33			
34	Minimum Head Required	(Total Head Loss + Static Head)	= 2.68 m

Sheet No.14
Head Loss Calculation- 1

1	Head loss calculation for	:	Cleaning cartridge filter to RO system
2			
3	Flow (cum/hr)	=	120 m ³ /hr
4	Diameter (mm)	=	150 mm
5	Hence, velocity (m/sec)	=	1.89 m/sec
6	Constant C	=	120
7	Straight length (m)	=	5 m
8	Static head (m)	=	1.5 m
9	Velocity Head ($v^2/2g$)	=	0.18 m
10			

Head Loss In Fittings

Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
15 Elbows, 90 deg	4	0.29	0.210
16 Elbows, 45 deg	0	0.14	0.000
17 Sudden contraction	0	0.94	0.000
18 Sudden engl.	1	1.89	0.342
19 Tee-90 deg	0	0.35	0.000
20 Valves	2	0.25	0.091
21 NRV	1	0.75	0.363
22 Strainer (approximate)	0	0.75	0.000
23 Exit	0	0.75	0.000
24 Total			1.006

Friction Loss in Pipes

27	According to the Empirical formulae for the calculation of friction loss:		
28	Friction head loss	$= 6.78 (v/C)^{1.852} (D)^{-1.165}$	0.028 m/m
29			
30	Therefore friction loss in pipe	5	0.14 m
31			
32	Total Head Loss (m)	Loss in Fittings + Friction Loss in pipe)	1.18 m
33			
34	Minimum Head Required	(Total Head Loss + Static Head)	2.68 m

Sheet No. 15
Head Loss Calculation

1 **Head loss calculation for** : **Recirculation line from RO system to Chem cleaning tank**

2		
3	Flow (cum/hr)	= 120 m3/hr
4	Diameter (mm)	= 150 mm
5	Hence, velocity (m/sec)	= 1.89 m/sec
6	Constant C	= 120
7	Straight length (m)	= 10 m
8	Static head (m)	= 1 m
9	Velocity Head ($v^2/2g$)	= 0.18 m

11 **Head Loss In Fittings**

13	Fitting	Quantity	Reynolds Factor (k)	Head Loss ($kv^2/2g$)
14				
15	Elbows, 90 deg	4	0.29	0.210
16	Elbows, 45 deg	0	0.14	0.000
17	Sudden contraction	0	0.94	0.000
18	Sudden engl.	0	1.89	0.000
19	Tee-90 deg	0	0.35	0.000
20	Valves	2	0.25	0.091
21	NRV	0	2	0.000
22	Strainer (approximate)	0	75	0.000
23	Exit	1	0.75	0.136
24	Total			0.437

26 **Friction Loss in Pipes**

27 According to the Empirical formulae for the calculation of friction loss:

28 Friction head loss = $6.78 \left(\frac{v}{100} \right)^{1.852} (D)^{-1.165}$ = **0.028 m/m**

30 Therefore friction loss in pipe 10 = **0.28 m**

32 Total Head Loss (m) (Loss in Fittings + Friction Loss in pipe) = **0.75 m**

34 Minimum Head Required (Total Head Loss + Static Head) = **1.75 m**

BRINE REJECT SYSTEM DESIGN CALCULATIONS

MMF Backwash	=	49.49 m ³ /hr
Brine RO	=	62.50 m ³ /hr

Total Waste Water discharge per day	=	1549.49 m³/Day
--	----------	----------------------------------

Total Waste Water Discharge per day from the PROPOSED PLANT with 10% margin	=	1704.44 m³/day
--	---	----------------------------------

SAMPLE COPY- EXCEL FILE ON PAID SECTION

DOSING CALCULATIONS

I Design of Pre chlorination - RO upstream

1	Feed Flow	=	111.87 m ³ /hr	
2	Pre – Chlorine dose	=	2.00 mg/l	
3	% Solution	=	20.00 %	
4	Chlorine rate	=	223.73 gm/hr	
5	Hypo chlorite Rate - 12 %	=	1864.44 gm/hr	
6	Solution Rate reqd	=	9.32 l/hr	@ 2.4 bar
7	Dosing Pump Cap	=	6.00 l/hr	@ 6.2 bar
8	Dosing Stroke adj	=	155.37 %	
9	Dosing Solution reqd per day	=	223.73 lit	
10	Dosing tank capacity provided	= *	100.00 lit	
11	Solution preparation frequency	=	11 hr	

II Design of Coagulant - RO upstream

1	Feed Flow	=	111.87 m ³ /hr	
2	Coagulant dose	=	5.00 mg/l	
2	% Solution	=	20.00 %	
3	Coagulant rate	=	559.33 gm/hr	
4	Ferric Chloride Rate - 33 %	=	1694.95 gm/hr	
5	Solution Rate reqd	=	8.47 l/hr	@ 2.4 bar
6	Dosing Pump Cap	=	6.00 l/hr	@ 6.2 bar
7	Dosing Stroke adj	=	141.25 %	
8	Dosing Solution reqd per day	=	203.39 lit	
9	Dosing tank capacity provided	= *	100.00 lit	
10	Solution preparation frequency	=	12 hr	

III Design of SMBS Dosing

1	Feed Flow	=	111.87 m ³ /hr	
2	Pre Chlorine dose	=	2.00 mg/l	
3	Sodium Metabisulphite dose	= *	5.00 mg/l	
4	% Solution	= *	10.00 %	
5	Dosing Rate	=	559.33 gm/hr	
6	SMBS Rate - 65 %	=	860.51 gm/hr	
7	Solution Rate	=	8.61 l/hr	@ 3.3 bar
8	Dosing pump cap	= *	6.00 l/hr	@ 6.2 bar
9	Dosing stroke adj.	=	143.42 %	
10	Dosing solution reqd. per day	=	206.52 lit	
11	Dosing tank capacity provided	= *	100.00 lit	
12	Solution preparation frequency	=	11.62 hr	

DOSING CALCULATIONS

IV Design of Antiscalant Dosing

1	Feed Flow	=	111.87 m ³ /hr	
2	Antiscalant dose	= *	5.00 mg/l	
3	% Solution	= *	6.00 %	
4	Dosing rate	=	559.33 gm/hr	
5	Antiscalant Rate - 100 %		559.33 gm/hr	
6	Solution Rate	=	9.32 l/hr	@ 3.3 bar
7	Dosing pump cap	=	6.00 l/hr	@ 6.2 bar
8	Dosing stroke adj.	=	155.37 %	
9	Dosing solution reqd. per day	=	223.73 lit	
10	Dosing tank capacity provide	=	100.00 lit	
11	Solution preparation frequency	=	10.73 hr	

V Design of Post Chlorination Dosing

1	Product Flow	=	41.67 m ³ /hr	
2	Post – Chlorine dose	=	2.00 mg/l	
3	% Solution	=	10.00 %	
4	Chlorine rate	=	83.33 gm/hr	
5	Hypochlorite Rate	=	694.44 gm/hr	
6	Solution Rate	=	6.94 l/hr	@ 3.3 bar
7	Dosing pump cap	=	6.00 l/hr	@ 6.2 bar
8	Dosing stroke adj.	=	115.74 %	
9	Post Dosing solution reqd per day	=	166.67 lit	
10	Dosing tank capacity provided	=	100.00 lit	
11	Solution preparation frequency	=	14.40 hr	

VI Design of Alkali Dosing

1	Product Flow	=	41.67 m ³ /hr	
2	Dosage	= *	2.00 mg/l	
3	% Solution	= *	2.00 %	
4	Dosing rate	=	83.33 gm/hr	
5	Alkali Rate %	=	166.67 gm/hr	
6	Solution Rate	=	8.33 l/hr	@ 3.3 bar
7	Dosing pump cap	=	6.00 l/hr	@ 6.2 bar
8	Dosing stroke adj.	=	138.89 %	
9	Dosing solution reqd. per day	=	200.00 lit	
10	Dosing tank capacity provide	=	100.00 lit	
11	Solution preparation frequency	=	12.00 hr	

PIPE SERVICE & SIZING DETAILS														
	1	2	3	4	5	6	7	8	9	10	11	12	13	14
SERVICE FLUID	Borewell pump to Raw Water Tank	Raw water tank to MF Feed Pump Suction	MMF Feed pump to MMF	MMF outlet to Cartridge filter Inlet	Cartridge filter outlet to High Pressure Pump & PX Suction	High Pressure pump suction line	PX suction line	High Pressure pump discharge line	PX discharge line	Brine disposal	Flush pump suction	Flush pump discharge to RO Modules	CIP Pump suction	CIP Pump discharge
Flow m3/hr	55.93	111.9	111.9	104.2	104.2	43.94	62.50	9.87	9.11	62.50	#####	120.0	120.0	120
Press. Bar	2.5	4.3	4.3	1.3	1.2	1.0	1.0	41.0	41.0	38.5	0.17	1.9	0.3	2.8
Pipe Size (mm).	150	150	150	150	150	100	100	50	50	100	150	150	100	150
Pipe Size Required(in)	6	6	6	6	6	4	4	2	2	4	6	6	4	6
MOC - PIPE	HDPE	UPVC	UPVC	UPVC	UPVC	UPVC	UPVC	Duplex SS	Duplex SS	UPVC	UPVC	UPVC	UPVC	UPVC

LIST OF DRIVES

Sl. No.	Description	Qty.				Capacity of pump m3/hr	Total discharge head m	Starter	Make	Model	MOC
		Duty	St/By	Store	Total						
		Nos	Nos	Nos	Nos						
1	Well Pump	2	1	0	3	55.93333333	25	DOL	Grundfos	SP	SS 904 L
2	Feed Water pump	1	1	0	2	115	43	VFD	Ampco	NB	DSS-2205
3	Backwash Pump	1	0	1	2	160	21	Star delta	Grundfos	NB	DSS-2205
4	High Pressure pump	1	0	1	2	43.9	720	VFD	Grundfos	BME	SS 904L
5	PX Booster pump	1	0	1	2	60.2	72	VFD	ERI PX booster model	HP-1253	DSS-CD3MC
6	Flush pump	1	0	1	2	75.00	30	DOL	Ampco	Z series	DSS-2205
7	CIP Pump	1	0	1	2	75.00	30	DOL	Ampco	Z series	DSS-2205
8	Air Scouring blower	1	0	0	1	274.00	5	DOL	Mapro	CL42/21	CI/MS
9	Dosing Pumps	13	13	0	26	Various		DOL	Jesco		PP/PVDF

SAMPLE COPY- EXCEL FILE ON P&ID SECTION

POWER CONSUMPTION OF RO PLANT EQUIPMENTS

Sl. No.	Description	Qty.				Capacity of pump	Total discharge head	Pump efficiency	BKW	Motor efficiency	Couplig loss	Power consumption	Working Hours / Day	Power consumption	Power requirement
		Duty	St/By	Store	Total										
		Nos	Nos	Nos	Nos	m3/hr	m	%	kw	%	%	kw	hr	kwhrperday	KW
1	Feed Water pump	1	1	0	2	115	43	75.0%	18.07	87%	98%	21.19	24.00	508.58	21.19
	Backwash Pump	1	0	1	2	160	21	68.0%	13.46	87%	98%	15.78	1.00	15.78	15.78
2	High Pressure pump	1	0	1	2	44	720	73.0%	118.02	87%	98%	138.42	24.00	3322.13	138.42
3	PX Booster pump	1	0	1	2	60	72	90.0%	13.12	87%	98%	14.71	24.00	353.13	14.71
4	Flush pump	1	0	1	2	75	30	67.0%	9.15	87%	98%	10.73	0.00	0.00	10.73
5	CIP Pump	1	0	1	2	75	30	67.0%	9.15	87%	98%	10.73	0.0000	0.00	0.00
6	Air Scouring blower	1	0	0	1	274	5	-	-	-	-	-	-	0.00	-
7	Dosing Pumps	13	13	0	26	Various	0	-	-	-	-	-	-	-	-
8	Instrumentation Load											0.50	24.00	0.00	0.00
TOTAL POWER CONSUMPTION														4199.63	200.84


1000
4.20
kwhr/m3

Sl. No.	Description	Qty.				Capacity of pump	Total discharge head	Pump efficiency	BKW	Motor efficiency	Couplig loss	Power consumption	Working Hours / Day	Power consumption	Power requirement
		Duty	St/By	Store	Total										
		Nos	Nos	Nos	Nos	m3/hr	m	%	kw	%	%	kw	hr	kwhrperday	KW
1	Well Pump	2	1	0	3	56	50	74.0%	10.29	82%	99%	12.68	18.00	456.41	25.36

25.36

Pump efficiency is considered on a conservative side

PX System Analysis



FLOW AND PRESSURE TABLE

		A	B	C	D	E	F	G	H
FLOW	US gpm	459	265	193	265	459	183	275	275
	m ³ /hr	104.2	60.2	43.9	60.2	104.2	41.7	62.5	62.5
	m ³ /day	2,500	1,445	1,055	1,445	2,500	1,000	1,500	1,500
PRESSURE	psi	23	23	1044	1015	1044	72.0	1022	15
	Bar	1.6	1.6	72.0	70.0	72.0	5.0	70.5	1.0
QUALITY	n/a	SEA	SEA	SEA	SEA	SEA	PERM	BRINE	BRINE

PX PERFORMANCE

PX model	n/a	PX-140S
Number of units	n/a	3
PX unit flow	m ³ /hr	20.8
PX lubricant per array	m ³ /hr	2.3
PX differential HP side	bar	0.5
PX differential LP side	bar	0.6
PX efficiency	%	95.0%
Operating capacity	%	65.5%

HIGH PRESS. PUMP POWER

HP pump efficiency	%	69%
Motor efficiency	%	92%
HP pump flow rate	m ³ /hr	43.9
Differential pressure	bar	70.4
Power	kW	136.2

PX BOOSTER PUMP POWER

ERI PX booster model	50 Hz	HP-1200
Number of units	n/a	2
PX booster efficiency	%	84%
Motor Efficiency	%	91%
Total PX booster flow rate	m ³ /hr	60.2
Differential pressure	bar	2.0
Total booster power	kW	5.8

SEA WATER FEED PUMP

	kW	0.0
--	----	-----

INPUT DESCRIPTIONS

INPUTS

Units Metric or English	M or E	m
Manual or auto efficiencies	m or a	a
Motor power Hz	50 or 60	50
Permeate flow	m ³ /day	570
RO recovery rate	%	40%
RO feed pressure	bar	72.0
Membrane DP	bar	1.5
Main HP Pump efficiency	%	
Main HP Pump motor efficiency	%	
PX Booster efficiency	%	
PX booster motor efficiency	%	
PX design margin	%	

PX SYSTEM POWER RESULTS

Total RO process (kW)	142.0
kWh/m ³ permeate	3.41
kWh/Kgal permeate	12.9

Power savings per year @ \$0.10/kWh	\$ 158,545
-------------------------------------	------------

Warnings	NONE
Suggestions	NONE

Notes: